

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-0554:126 Page 1 of 1

CATEGORY: Misc. Device/Control Unit Accessories

LISTEE: Johnson Controls, Inc., 507 E. Michigan Street, Milwaukee, WI 53202-5211*
Contact: *James D. Kinney (414) 524-4358 Fax (414) 276-5979

DESIGN: Model **Fire OWS** (Operator Work Station) proprietary receiving unit. Unit consists of models ULOWS-PC-FIRE computer, ULOWS-TS-FIRE touch screen and ULOWS-CRT-FIRE monitor, WD-TIMER-FIRE watchdog enclosure and NU-NCM300-FIRE interface. The unit is intended for use with model IFC-1010/2020 fire alarm control unit (CSFM Listing No. 7165-0554:104 and 7170-0554:111) to form a proprietary system. Refer to listee's printed data sheet for additional detailed product description and operational considerations.

RATING: 120 VAC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as control unit accessories for use with listee's separately listed Model IFC-1010/2020 fire alarm control units.

*Rev. 06-10-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 10, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager